



MEADIA VOLUME: 413.4 CU. FT.

NOZZLE SCHEDULE				
MARK	REQ'D	SIZE	TYPE	SERVICE
N1	1	8"	150# FF	INFLUENT
N2	1	8"	150# FF	EFFLUENT
N3	1	3"	150# FF	REJECT
N4	1	4"	150# FF	CLEANOUT
N5	1	2"	NPT	DRAIN
N6	1	1"	NPT	AIRLIFT LUB.
N7	1	1/2"	FNPT	HEADLOSS INDICATOR

THIS DRAWING IS THE PROPERTY OF APPLIED PROCESS TECHNOLOGY, INC. IT IS NOT TO BE USED, DISCLOSED, OR REPRODUCED IN ANY MANNER, WITHOUT THE EXPRESSED WRITTEN PERMISSION OF APPLIED PROCESS TECHNOLOGY, INC.

REVISIONS					
REV	DATE	BY	APPV'D	DESCRIPTION	
A	10/29/04	PS	JS	ISSUED FOR COMMENTS	
B	3/9/05	PS	JS	ADDED MEDIA VOLUME / LOADINGS	
C	4/1/05	PH	JS	UPDATED MEDIA VOLUME / LOADINGS	



**CENTRA-FLO GRAVITY SAND FILTER
CF-50UF W/ 80" BED GENERAL ARRANGEMENT**

DRAWN BY: P. SIMON	DATE: 10/29/04	DWG. NO.: CF-50-80UFGA
CHK'D BY: J. STEVENS	SCALE: 1"=1'-0"	SHT 1 OF 1
CAD FILE: CF-50-80UF GA	JOB NO:	REV: C